



GOVT. OF WEST BENGAL.
OFFICE OF THE EXECUTIVE ENGINEER
JALPAIGURI DIVISION, P.H.E DTE. JALPAIGURI
JALPAIGURI DIVISIONAL LABORATORY

REPORT OF WATER QUALITY TEST (Chemical & Physical & Bacteriological)

Date of Sample Receiving :11/06/2025

Ref. of Charges:GRN No.192025260104757675

Date of Sample Testing : 11/06/2025


M.R. No. Pg No-057/Book No-02

SL. NO.	NAME OF LOCATION	TYPE OF WATER SOURCE	CHEMICAL & PHYSICAL PARAMETER					BACTERIOLOGICAL PARAMETER (CFU= Colony forming unit)		Remarks
			Iron (mg/L)	TDS (mg/L)	Total Hardness (mg/L)	Turbidity (NTU)	pH	T.C (CFU/ 100ml)	F.C (CFU/ 100ml)	
1	HIMALAYAN PUBLIC SCHOOL, DHUPGURI.	FILTER WATER	0.156	123	44	1.74	6.65	0	0	
Permissible Limit for Drinking Water as per IS 10500:2012			1	2000	600	5	6.5-8.5	0	0	

N.B: The test done with the Sample as deposited by the party.

Depositer name/ Client Name: PRINCIPAL, HIMALAYAN PUBLIC SCHOOL, DHUPGURI.


CHEMIST
DISTRICT WATER TESTING LAB
P.H.E.Dte


BACTERIOLOGIST
DISTRICT WATER TESTING LAB
P.H.E.Dte


JUNIOR ENGINEER
IN CHARGE OF LABORATORY
P.H.E.Dte


ASSISTANT ENGINEER
JALPAIGURI R.W.S SUB DIVISION,
P.H.E.Dte


EXECUTIVE ENGINEER
JALPAIGURI DIVISION
P.H.E.Dte