



Government Of West Bengal
Office Of The Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services
Jalpaiguri Fire Station, Race Course Para,
P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo no: FSR/0125186217900199

Date: 31-07-2022

From:

Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services

To: HIMALAYAN PUBLIC SCHOOL

WARD NO: 13, P.O..AND P.S. :: DHUPGURI , DIST. JALPAIGURI , PIN: 735210

Sub: Fire Safety Certificate in favour of Himalayan Public School, under group of G+1 storied educational building.

This is in reference to your application no. 0125189227900093 dated 16-07-2022 regarding the Fire Safety Certificate in favour of Himalayan Public School, under group of G+1 storied educational building.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:


- 1) Regular checking, testing and maintenance of fire safety systems/installations are must.
- 2) Good housekeeping to be maintained.
- 3) Regular checking and maintenance of electrical wiring and installation by a licensed Electricians.
- 4) Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5) Certificate shall have to be obtained from this Office on routine basis about the satisfactory performances off all the fire and life safety installations failing which the Fire Safety Certificate shall be revoked as per rule 18 of the W.B. fire Services (Fire Prevention & Fire Safety) Rules, 2003.
- 6) Fire License shall be obtained from this department separately which are attracts section 12 of FS Act.
- 7) This certificate needs to be renewed after 3(three) yrs as per notification subject to ensure safety first and all safety measures should be in working condition at all time failing which this certificate will automatically liable to be cancelled.
- 8) Occupancy of the building shall not be allowed to change without the concurrence of this department and floor area, height etc. shall not permissible to enhance without the concurrence of this department. No addition or alteration should be allowed without the prior approval of this department. For hostel facilities separate permission to be taken from this department.
- 9) Two staircases should be free from any obstruction at all time

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125189227900093

Page 1

Manager
Himalayan Public School
Dhupguri, Jal

Principal
Himalayan Public School
Dhupguri, Jal




10) Auto panel pumps and all safety measures should be in working condition at all time and if any defects or if found the safety measures not in working condition then this certificate will automatically liable to be cancelled in the life safety point of view or it will be revoked in the same causes.

Signature valid

Digitally Signed
Name: PROUDIP
Date: 31-Jul-2023 12:12
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services


Manager
Himalayan Public School
Dhupguri, Jal


Principal
Himalayan Public School
Dhupguri, Jal